

Compliance Statement

No. 2022-276

Screened Permanent Link, Class E_A

Company

SOCAMONT Industries
ZI des Touches
9 rue des frères Lumière
53000 LAVAL
France

Permanent Link Identification (3 connector model)

Horizontal cable:

Platine Réseaux Câble Cat6_A FFTP LS0H 4 Paires 10 GBit 100ohms AWG23 - PN:6710
Platine Réseaux Câble Cat6_A FFTP LS0H 2x4 Paires 10 GBit 100 ohms AWG23 - PN:6711

RJ45 connector for telecommunications outlet, consolidation point, and patch panel:

Platine Réseaux Jack COCCINELLE RJ45 Cat6_A FTP 10GIGA - PN:71009

Including use with:

Wall Outlet: Platine Réseaux Plastron 1 entrée inclinée DIM 45 X 45 une entrée - PN:71227
Patch Panel: Platine Réseaux Panneau non équipé 24 ports FTP à accroche Keystone 1U - PN:71007

Generic cabling standards - Class E_A Permanent Link requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

Technical report

12223612-02, DANAK-19/22629

EC Cabling product ID


5370

CS valid until

1 June 2023

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 27 April 2022



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department

